

Issue Date: October 4, 2017

## INDUSTRY NOTICE

### Transformer-Type Meter and Metering Transformer Enclosure/Compartment Options

Effective November 15, 2017, Manitoba Hydro will only supply **5-jaw**, 20amp, 240volt, 1-ph meter types for new single-phase services rated 400 amp and over.

Contractors have the following accepted meter enclosure options for the 5-jaw meters:

**For single-phase services 400 amp with a transformer rated meter mounting device:**

A 5-jaw socket, c/w 4-pole test switch, 120/240Volt, Single-Phase 3-wire service

- Thomas & Betts, Model JS4B-TWLMH
- Hydrel, Model CT4-TSMB
- Eaton, Model TCC5-MH
- Thomas & Betts, Model JS4B-TWLEALMH

**For single-phase services 400 amp and over using a CSTE or CT Cabinet**

A 5-jaw socket, c/w 4-pole test switch, 120/240Volt, Single-Phase 3-wire service

- Thomas & Betts, Model CT105-SWLMH
- Hydrel, Model CTS405PW-TSMB
- Eaton, Model TSU5-MH
- Durham, Model URSTL5-2A805

**Note:** Information will be posted at [www.hydro.mb.ca/ecs](http://www.hydro.mb.ca/ecs) if additional manufacturer's enclosures become available.