



Manitoba Electrical Code Inspection Notice

26-250 Overcurrent protection for power and distribution transformer circuits rated over 750 V

Effective Date:

Immediately

Scope:

This inspection notice will bring rule 26-250 into compliance with rule 36-204.

Requirements:

Rule 26-250(3)(4)

Subrule (3) and (4) of rule 26-250 (overcurrent protection for power and distribution transformer circuits rated over 750 V) is struck out.

Rationale:

The scope of Section 36 supplements or amends the general requirements of the electrical code. As section 26 is a general section of the code, the rules pertaining to high voltage installations are amended by the rules of section 36. By striking out these subrules, we bring rule 26-250 into compliance with rule 36-204.

Supporting Information:

Manitoba Electrical Code: Section 26 and section 36

Issued By

Manitoba Hydro
Electrical Codes and Standards