

## Informative Note: 12-3014

### Accessibility of junction boxes

This Informative Note is to provide code users with guidance on determining the accessibility of pull in, junction and outlet boxes, cabinets, and gutters.

Every effort has been made to ensure the accuracy of the information being provided. However, in the event of a discrepancy between this informative note and the governing Manitoba Electrical Code, The Manitoba Electrical Code shall take precedence.

Remember, the Manitoba Electrical Code is constantly being updated. Be sure to familiarize yourself with the latest code requirements before you begin your installation.

Manitoba Hydro will not accept the installation of the “bocci” style receptacles. These receptacles do not allow proper access to the outlet box as required by the Manitoba Electrical Code rule 12-3014 1). This is in part due to the narrow 32mm (1.25-inch diameter) hole for access to any connections. A special tool is also required to remove the outlet.

To request accessible formats visit [hydro.mb.ca/accessibility](http://hydro.mb.ca/accessibility).