

## Informative Note: 2-200

### Protection of persons and property

---

This informational note is designed to help you install electrical equipment where it will provide protection of persons and property.

Every effort has been made to ensure the accuracy of the information being provided. However, in the event of a discrepancy between this informative note and the governing Manitoba Electrical Code, The Manitoba Electrical Code shall take precedence.

Remember, the Manitoba Electrical Code is constantly being updated. Be sure to familiarize yourself with the latest code requirements before you begin your installation.

Manitoba Hydro's interpretation of rule 2-200 is that buildings shall be secure and weatherproof prior to energization. This will include but not be limited to completed roof coverings and all door and window openings shall be adequately covered and secured against moisture and unauthorized entry. Where windows or doors are not yet installed, temporary coverings at least the minimum size thickness of the wall sheathings are acceptable. Permanent stairs conforming to the Manitoba Building Code must be installed to provide ready access to service equipment and panelboards.

Available in accessible formats upon request

