

Effective Date:

Immediately

Manitoba Electrical Code Inspection Notice

28-900 Disconnecting means required for generators

Scope:
To clarify when an additional disconnecting means for a standby generator will be permitted.
Requirements:
Rule 28-900(4)
For the application of subrule 1, a load box disconnect that is interlocked with the main disconnecting means or has a shunt trip scheme will only be considered as having one main disconnecting means.
Rationale:
We will allow you to have an additional disconnect for a load box
Supporting Information:

Issued By

Manitoba Hydro Electrical Codes and Standards

Manitoba Electrical Code: Section 28